

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 6911-0785:129 Page 1 of 1

CATEGORY: Voice Communication System Control Units

LISTEE: Wheelock Inc., 273 Branchport Avenue, Long Branch, NJ 07740  
Contact: Luy Nguyen (732) 222-6880 Fax (732) 222-5607

DESIGN: Model SAFEPATH (P/N SAPE-1AB, -2AB, -1AR, -2AR and RSAPE-B, -R) voice evacuation/emergency message panel. The units are modular in construction. System components:

SAMB	Supervised Audio System Motherboard
SADC, SADC-A *	Supervised Audio Controller
SAA-40	Supervised Audio Amplifier
SAPS	Supervised Power Supply Module
SABC	Supervised Audio Battery Charger
BATC-B, -R	Battery Enclosure
DX-100, -200	Digital Voice Repeater
SALL-15S	Self Amplified Signal Module
SAA-10S, -10SE	Supervised Audio Amplifier
SAA-40S, -40SE	Supervised Audio Amplifier
SAA-80S, -80SE	Supervised Audio Amplifier
SACC-A	Supervised Audio Control Module
SAMB-A	Supervised Audio System Motherboard
RMS-1B, -1R, -2B, -2R	Remote Microphone
SPL	Zone Splitter Module
NACIM	Notification Circuit Interface Module
LLIM	Remote Safepath Interface Module
AIM-3*	Auxiliary Input Module
RAM-1*	Redundant Amplifier Module

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Primary: 120 VAC, 8A; Secondary: 24 VDC, 3A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as voice evacuation/emergency system when used in conjunction with separately listed electrically compatible fire alarm control units.

\*Rev. 06-04-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**