

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 6911-0785:147 Page 1 of 1

CATEGORY: Voice Communication System Control Units

LISTEE: Wheelock Inc., 273 Branchport Avenue, Long Branch, NJ 07740
Contact: Luy Nguyen (732) 222-6880 Fax (732) 222-5607

DESIGN: Model "SAFEPATH" DCSP-B and DCSP-R single and dual zone voice evacuation/emergency message panel. The panels are single or dual zone paging systems which can also be used for emergency communication and relocation equipment. The units are modular in construction. System components:

DCSP	Motherboard
DCDC	Supervised Audio Controller Card
MDX-2	Digital Voice Repeater
SACM-4	Self Amplified Signal Module
RMS-3B, -3R	Remote Microphone Station
SALL-15S	Self Amplifier Signal Module
SAA-40S, -40SE, -10S, -10SE	Supervised Audio Amplifier
SAA-40, SAA-80S, -80SE	Supervised Audio Amplifier
SC-SPL-B, -R	Four Zone Splitter
NACIM	Notification Circuit Interface Module
DCMB*	Motherboard
DCPS*	Dual Circuit Power Supply
PSC-2420*	Dual Circuit Power Supply w/ Charger
DCSP-1BP*, -1RP*, -4BP*, -4RP*	System Package
DCSP-8BP*, -8RP*, -15SP-R*, -15SP-B*	
DCSP-R*, -B*, -PS-R*, PS-B*	

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Primary: 24 VDC, 7A Maximum

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as voice evacuation/emergency system when used in conjunction with separately listed electrically and functionally compatible fire alarm control units.

*Rev. 07-20-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager